

Oregon Office of State Fire Marshal

Smoke and Carbon Monoxide Alarm Power Source and Hush Feature Requirements



For questions, contact the OSFM Education Branch at 503-934-8228 or osfm.ce@state.or.us.

Alarm Type	Hush Feature Requirements	Lithium (long life) Battery Requirements	Battery Back-up Requirements
Photoelectric smoke alarm (battery operated)	No	No	NA
Photoelectric smoke alarm (hardwired)	No	No	YES
Ionization smoke alarm (battery operated)	YES	YES	NA
Ionization smoke alarm (hardwired)	YES	No	YES
Ionization/photoelectric smoke alarm (battery operated)	No	No	NA
Ionization/photoelectric smoke alarm (hardwired)	No	No	YES
Ionization/carbon monoxide combination (battery operated)	No	No	NA
Ionization smoke alarm/carbon monoxide alarm (hardwired)	No	No	YES
Photoelectric smoke alarm/carbon monoxide alarm (battery operated)	No	No	NA
Photoelectric smoke alarm/carbon monoxide alarm (hardwired)	No	No	YES
Carbon monoxide alarm (battery operated)	No	No	NA
Carbon monoxide alarm (plug-in)	No	No	YES

For more information about smoke or carbon monoxide alarms visit the Oregon Office of State Fire Marshal website at www.oregon.gov/osp/sfm.